



1 February 2024

Scott McCullough
Douglas County
1594 Esmeralda Avenue
Minden, Nevada 89423

Subject: Douglas County Records Division
Storage Fire Suppression System

Dear Mr. McCullough:

Please include the following items in an addendum to the bid documents for the above referenced project.

- 1) The requirement of Class A (or class 1) circuiting is not required. The contractor shall provide Class B circuiting for this project.
- 2) There are two (2) existing fire suppression control panels which will be required to be connected to the new fire alarm control panel, not one (1) as shown.

If you have any questions, please do not hesitate to contact my office.

Respectfully for **JP Engineering, LLC,**



James Solaro, PE
Principal Engineer