



NOTES:

1. SPACING OF WEAKENED PLANE JOINTS SHALL BE 12' MAXIMUM.
2. TRANVERSE WEAKENED PLANE JOINTS SHALL BE CONSTRUCTED AT LEAST 6' FROM ANY TRANSVERSE CONTACT JOINT.
3. LONGITUDINAL WEAKENED PLANE JOINTS SHALL BE CUT AT ALL LANE LINES.
4. STRUCTURAL SECTION TO BE DETERMINED BY ENGINEERING DESIGN, BUT IN NO CASE SHALL THE CONCRETE BE LESS THAN 6" THICK AND THE AGGREGATE BASE LESS THAN 8" THICK.
5. AGGREGATE BASE SHALL BE TYPE 2, CLASS B AND BE CONSTRUCTED IN CONFORMANCE WITH SECTION 308 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
6. PORTLAND CEMENT CONCRETE SHALL CONFORM TO THE REQUIREMENTS OF SECTION 202 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION FOR CONCRETE EXPOSED TO FREEZE-THAW ENVIRONMENTS.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
			<h1>PCC ALLEY JOINTING DETAILS</h1>	DOUGLAS COUNTY
				DATE: JULY 2017
				DWG: A10-B