



NOTES:

1. ALL SERVICE LINE COUPLING FITTINGS SHALL BE MUELLER IPS 110 COUP. X MIP OR APPROVED EQUAL.
2. THE METER SHALL BE LOCATED AT A POINT AS CLOSE AS PRACTICABLE TO THE PROPERTY LINE, ALLEYS, OR EASEMENTS.
3. NO DUAL 1-INCH SERVICE IN GARDNERVILLE WATER COMPANY SERVICE AREA.

NO.			REVISION			DATE			STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION			SECTION: DOUGLAS COUNTY		
<h1 style="margin: 0;">1" DUAL METER SET</h1>									DATE:			JULY 2017		
									DWG:			B07		