



NOTE: ALL JOINTS AND CONNECTIONS SHALL BE WATERTIGHT.

NOTES:

1. CLEANOUTS TO BE PLACED AT EVERY ANGLE GREATER THAN, OR EQUAL TO 45°, EVERY 150' OF LATERAL, AND WITHIN 5' OF BUILDING AND IN CONFORMANCE WITH THE CURRENT EDITION OF THE UNIFORM BUILDING CODE. CLEANOUTS INSTALLED AT ANGLES SHALL BE LOCATED ON THE UPSTREAM SIDE OF THE ANGLE. CLEANOUTS SHALL BE LOCATED AS CLOSE AS PRACTICAL TO THE ANGLE.
2. CLEANOUT SHALL NOT BE LOCATED WITHIN A ROADSIDE DITCH UNDER ANY CIRCUMSTANCES.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION: DOUGLAS COUNTY
			SEWER LATERAL CLEANOUT	DATE: JULY 2017
				DWG: C07